



**CITY OF STAYTON**  
**M E M O R A N D U M**

**TO: Mayor Henry Porter and the Stayton City Council**  
**FROM: Ian Kintz-Stormo**  
**DATE: January 4, 2021**  
**SUBJECT: Public Works Monthly Operating Report- December 2020**

**KEY ACTIVITIES**

**STATUS**

- **WWTP Facility** Effluent flows: 71.00 million gallons were treated during December. The highest Daily flow was 5.36 million gallons on December 21<sup>st</sup> and the lowest flow was 1.31 million gallons on the 5<sup>th</sup>. The average flow was 2.29 million gallons. Total rainfall for December was 8.67 inches. 2 yards of Santiam Green were hauled off site in December.
- **WTP** Highest production day was 2,722,000 gallons on December 11<sup>th</sup>.
- **Water System** Replaced 3 water meters and 1 radio reader. Water service repair at 1475 Second Ave. Cleaned number 3 slow sand filter bed.
- **Streets** Swept 135 curb miles and 35 cubic yards of material was collected. Collected 60 cubic yards of material for fall cleanup. 360 lbs of food and \$45.00 were donated to the food bank.
- **Parks** None for December 2020.
- **Building Permits**

<b>Permit Type</b>	<b>Issued</b>	<b>SDC's Paid</b>
Residential New Single Family Dwelling	7	\$79,971.01
Residential Structural	2	-
Commercial Structural	5	-
<b>TOTAL</b>	<b>1</b>	<b>\$79,971.01</b>

*Note: Typical SDC fees for one (1) Residential SDC = \$12,013.00 + Storm Water SDC \$2,118.00 or \$3,037.00 + \$781.00 for Mill Creek SDC (if within Mill Creek Sewer Project Area)*

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the main Public Works web page: [http://staytonoregon.gov/page/pw\\_home](http://staytonoregon.gov/page/pw_home)