



CITY OF STAYTON
M E M O R A N D U M

TO: Mayor Brian Quigley and the Stayton City Council
FROM: Windy Cudd, Office Specialist
DATE: October 14, 2024
SUBJECT: Public Works Monthly Operating Report- September 2024

KEY ACTIVITIES

STATUS

- **WWTP Facility** Effluent flows: 30.03 million gallons were treated during September. The highest Daily flow was .96 million gallons on the 11th and the lowest flow was 0.84 million gallons on the 6th. The average flow was 0.90 million gallons. Total rainfall was 1.0 inches. No bio solids were hauled off site.

- **WTP** Highest production day was 4,750,000 gallons on September 27, 2024.

- **Water System** Replaced 2 meters. Replaced 11 meter boxes. Repaired 4 water service lines.

- **Streets** Swept 120 curb miles with 16 cubic yards of material removed from the streets. 2 yards of gravel applied to gravel roads.

- **Parks** 47 volunteers with 107 hours of volunteer time September 2024

- **Building Permits**

<u>Permit Type</u>	<u>Issued</u>	<u>SDC's Paid</u>
Residential New Single-Family Dwelling	0	-
Residential Structural	2	-
Commercial Structural	0	-
TOTAL	2	-

Note: Typical SDC fees for one (1) Residential SDC = \$12,722.00 + Storm Water SDC \$2,242.00 or \$3,216.00 + \$827.00 for Mill Creek SDC (if within Mill Creek Sewer Project Area)

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page: